

SETTING SIEMENS CONTROLLER FOR AIR CONDITIONER



Switch on air conditioner.

Press and hold ^ and v buttons for 5 seconds, then release.

Press and hold ^ button for 5 seconds.

Display should show P00.

(NB - If display shows 0.0°C, you have held buttons for longer than 5 seconds.)

Using enter button, scroll through settings P00, P01 etc as shown on next page. Adjust values as required using ^ and v buttons.

Values to be adjusted include the symbols at bottom of display ie

(H) – Heating (3 wiggly lines)

(C) – Cooling (circle with 6 points)

(F) – Small fan (triangle with 3 lobes)

(FFF) – 3 fans

(FFFA) – 3 fans and AUTO

(NB - If air conditioner is heating instead of cooling, check symbol for setting P06.)

P00	XX°C
P01	OFF (H)
P02	OFF (C)
P03	00s TOFF
P04	00s TON
P05	0.5°C DB (H) (C)
P06	RVON (H)
P07	00s DLY (H) (F)
P08	00s DLY (C) (F)
P13	100% HIG (FFFA)
P14	65.00% MED (FFFA)
P15	10% LOW (FFFA)
P18	0.5°C PB (H)
P19	0.5°C PB (C)
P20	0 IGT
P23	HC DB (FFF)